

New Construction Checklist

Exterior Siding, Flashing, & Trim

 Cracks in brick or stone veneer siding. Stone veneer siding that's lacking mortar, missing a weep screed, and/or is in contact with the roof surface. Fiber cement siding that's lacking sealant. Warped or damaged vinyl siding. Vinyl siding panels that aren't overlapped at the ends. Exposed wooden framing due to missing flashing. Missing box trim around outdoor faucets. 	vith
Driveway, Sidewalk, & Garage Floor	
Surface cracks Flaking or peeling concrete.	
Exterior Grading & Drainage	
 Level grade around the home's perimeter. Missing downspout extensions or splash blocks. Foundation vents located at or below the finished grade. 	
Decks, Porches, & Patios	
 Wooden posts that are improperly fastened to the patio or deck overhang. Excessively warped or bowed posts. Surface cracks on concrete slabs. 	
Roof	
 Debris on surface (i.e., scrap shingles, flashing materials, nails). Missing or improperly installed kickout flashing. Inadequate shingle overhang above covered patios. Improperly installed shingles near roof penetrations. 	
Exterior Doors	
 Missing, unsecured, or inadequate weatherstripping. Unsealed door casings & thresholds. Interference between doors and side jambs while closing. Misaligned strike plates that prevent the door from latching or locking with the deadbold Loose or missing hardware. Exposed garage door side jambs. 	t.

Windows
 Unsealed window frames. Missing or poorly fitted glazing beads. Cracked glass. Damaged tilt latches or sash vent stops. Windows that are difficult to open or fully lock. Missing screens.
Appliances
 Debris in garbage disposal. Missing high loop along dishwasher drain hose. Missing dishwasher toe plate. Interference between the cabinets and dishwasher door. Missing charcoal filters on the microwave. Loose built-in cooktop.
Counters & Cabinets
 Unsealed countertops. Unsecured side splashes on bathroom vanity tops. Interference between cabinet doors while opening/closing. Loose cabinet door hardware.
Interior Doors
 Loose or missing hardware. Door interference while opening/closing. Doors that won't latch or lock properly. Material damage.
Interior Walls & Ceilings
 Drywall cracks, nail pops, and separation along seams. Missing box trim around the refrigerator & washing machine shutoff valves Bowed walls.
Floors
 Cracked or loose tiles. Missing or separated tile grout. Missing baseboard or quarter-round moulding. Squeaky or springy floors. Material damage.
Stairways
Loose or missing handrail. Loose or squeaky stair treads. Unsecured baluster shoes.

Plumbing	
Shower head leaks. Drain pipe leaks. Leaks at water distribution pipe fitti Unsecured distribution pipes in craw Missing distribution pipe insulation Unsecured plumbing fixtures. Missing or incorrectly sized drain tu valve. Missing or separated tile grout in sh Low water pressure at whirlpool tub Unsecured whirlpool tub motor. Unsealed shower door frames.	w spaces. in crawl spaces and garages. be for the water heater temperature-pressure relience.
Electrical	
Missing or cracked light fixture glob Missing light bulbs. Exposed and/or loose service groun Unlabeled circuit breakers. Missing smoke detector batteries. Loose receptacles. Missing receptacle or light switch of Missing conduit on exposed electrical Missing cable clamps or bushings. Nuisance tripping of GFCI receptact Poorly secured electrical cables in of Flickering lights. Loose Ceiling fans.	over plates. cal cables. les or breakers
Heating & Cooling	
Low heating/cooling efficiency in both Poorly sealed ductwork. Debris in floor vents (mainly found round roundensate drip tubes that terminate Dirty air filters. Unsecured equipment disconnects Unsealed exterior duct shrouds. Missing vent registers.	near tile flooring). te next to the home's foundation.
Insulation & Ventilation	
 Missing or unsecured floor, attic, an Dryer vent hoods equipped with sci Soffit vents blocked by insulation. Bathroom exhaust fans that aren't vertex. 	reens.
Framing	
Weak rafter and ridge board connection Missing floor joist hangers.	ctions.

Improperly sistered rafters Missing rafter collar ties.			
Slab Foundations			
Exposed foundation aggregate or rebar.			
Crawl space Foundations			
Unsealed wall penetrations. Missing positive drain. Standing water along foundation walls. Missing or incomplete vapor barrier. Discarded wood on the crawl space floor. Missing or undersized floor girder shims. Missing or loose nuts on foundation anchor bolts. Concrete block cracks and mortar joint separation. Poorly fastened steel columns. Column base plates that are in contact with the soil. Tilted concrete block piers. Poor crawlspace grading.			
Basement Foundations			
 Unsealed wall penetrations. Signs of moisture intrusion or efflorescence along walls. Concrete block cracks and mortar joint separation. Poorly fastened steel columns. 			